

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 13-51-09735 Name of Facility: COPE Center North Address: 9950 NW 19th Avenue City, Zip: Miami 33147  Type: Public Schools Owner: MDCPS Person In Charge: Dr. Ebony N. Dunn      Phone: 3058363300 PIC Email: ebonyndunn@dadeschools.net	<b>Correct By: Next Inspection</b> <b>Re-inspection Date: None</b>
--	---

**Inspection Information**

Purpose: Routine Inspection Date: 5/22/2024	Begin Time: 01:11 PM End Time: 02:57 PM
--	--

**Additional Information**

FEMALES ..... 37 MALES ..... 0	CENSUS ..... 37
-----------------------------------	-----------------

*This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.*

**Violation Markings**

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation OUT 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms IN 12. Toilet Facilities OUT 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other
--	---	--

*Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation*

*Violation Key: \* = 2. Playground, Equipment & Athletic Fields*

**General Comments**

Satisfactory.
Email Address(es): ebonyndunn@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

Violations Comments

**Violation #5. Maintenance & Repair**

Observed ceiling lighting fixtures with light tubes burn out in classroom 72. Replace light tubes.  
Observed missing wall outlet covers in classrooms 22 and 39. Replace covers.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

**Violation #9. Mechanical Ventilation**

Observed exhaust fans not functioning in bathrooms 2, 27 and 44. Repair/Replace exhaust fans.

CODE REFERENCE: 9. Mechanical Ventilation. 5(16)(a)2 SREF. Mechanical ventilation systems shall be maintained in an operable condition at all times. 5(16)(a)4 SREF. Exhaust systems from toilet rooms, custodial closets, shower and locker rooms, athletic equipment rooms, etc., shall be maintained in an operable condition at all times. 5(13)(g)1.d SREF. Toilet rooms shall have exhaust fans vented to the exterior. 5(16)(a)10 SREF. Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be irritating or injurious to human health shall have an exhaust system to collect and remove the contaminants. Such exhaust shall discharge directly to the exterior of the building. 468.3.6.2 FBC and 468.3.6.3 FBC. Kiln rooms and areas shall be provided with adequate exhaust to dispel emitted heat to the exterior, and they shall not be connected to any other exhaust system. 5(16)(a)5 SREF. Science laboratory fume hoods and laboratory emergency fans shall be maintained in an operable condition. 468.3.6.4 FBC. HVAC systems in chemistry labs and science classrooms shall be designed and installed to ensure that chemicals originating from the space are not recirculated. 468.3.6.5 SREF. Rooms used for the storage, handling, and disposal of chemicals used in school, college, and university laboratories shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.

**Violation #13. Handwashing Facilities**

Observed handwashing sinks not providing water in bathroom 27 (1 out 2 handwashing sinks). Repair handwashing sink.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Vicente Prietodiaz (31113)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name: Kecia Smith Blissett  
Date: 5/22/2024

Inspector Signature:

Handwritten signature of Vicente Prietodiaz.

Client Signature:

Handwritten signature of Kecia Smith Blissett.